

Lead Based Paint Inspection by Enviro-Test for John Andrews
Serial #XL309-U2051NR7963 11th Street Brooklyn, NY (upstairs) Date: 11/14/2006

No	Site	Insp	Flr	Side	Room	Source	Sub	Feat	Cnd	Ssec	Date/Time	DI	Result	Pbc ± Prec
1	462A UP	JS			Calibrate	XRF		Lead Standard 0.3	OK	5.0	11/14/2006 09:23:39	1.0	NEG	0.28 ± 0.11
2	462A UP	JS			Calibrate	XRF		Lead Standard 0.0	OK	7.2	11/14/2006 09:23:53	1.0	NEG	0.00 ± 0.01
3	462A UP	JS			Calibrate	XRF		Lead Standard 1.0	OK	22.8	11/14/2006 09:24:07	1.0	POS	1.01 ± 0.12
4	462A UP	JS	1	B	Vestabule	Wall	Plaster		Intact	4.4	11/14/2006 09:26:16	2.6	POS	35.28 ± 6.13
5	462A UP	JS	1	C	Vestabule	Wall	Plaster		Intact	3.0	11/14/2006 09:26:35	4.5	POS	37.76 ± 12.95
6	462A UP	JS	1	D	Vestabule	Wall	Plaster		Intact	4.7	11/14/2006 09:26:52	3.1	POS	28.80 ± 5.06
7	462A UP	JS	1	D	Vestabule		Wood	Baseboard	Intact	2.5	11/14/2006 09:27:11	1.6	POS	23.77 ± 9.17
8	462A UP	JS	1	D	Vestabule		Wood	Chair rail	Intact	2.4	11/14/2006 09:27:24	1.2	POS	5.10 ± 1.69
9	462A UP	JS	1	D	Vestabule	Wall	Plaster		Intact	2.5	11/14/2006 09:27:38	1.6	POS	29.49 ± 10.93
10	462A UP	JS	1	B	Vestabule	Wall	Plaster		Intact	2.5	11/14/2006 09:28:01	1.7	POS	21.09 ± 9.56
11	462A UP	JS	1	A	Vestabule	Door	Wood	Door	Intact	2.3	11/14/2006 09:28:18	1.5	POS	19.87 ± 7.76
12	462A UP	JS	1	A	Vestabule	Window	Wood	Transom	Intact	2.3	11/14/2006 09:28:40	1.5	POS	19.94 ± 8.38
13	462A UP	JS	1	C	Vestabule	Door	Wood	Jamb	Intact	3.0	11/14/2006 09:29:11	1.0	NEG	0.03 ± 0.05
14	462A UP	JS	1	A	Vestabule	Door	Wood	Casing	Intact	2.3	11/14/2006 09:29:32	1.5	POS	21.56 ± 8.52
15	462A UP	JS	1	A	Vestabule	Door	Wood	Jamb	Intact	2.6	11/14/2006 09:29:55	1.6	POS	19.87 ± 7.84
16	462A UP	JS	1	A	Vestabule	Ceiling	Plaster		Intact	3.1	11/14/2006 09:30:18	10.0	POS	42.93 ± 9.60
17	462A UP	JS	1	A	Hall	Wall	Plaster		Intact	3.1	11/14/2006 09:30:47	10.0	POS	28.83 ± 7.96
18	462A UP	JS	1	B	Hall	Wall	Plaster		Intact	3.2	11/14/2006 09:30:59	2.9	POS	18.04 ± 6.22
19	462A UP	JS	1	C	Hall	Wall	Plaster		Intact	7.7	11/14/2006 09:31:12	1.0	NEG	0.00 ± 0.01
20	462A UP	JS	1	D	Hall	Wall	Plaster		Intact	3.1	11/14/2006 09:31:32	7.0	POS	27.26 ± 7.40
21	462A UP	JS	1	D	Hall		Wood	Baseboard	Intact	2.5	11/14/2006 09:31:56	1.4	POS	5.10 ± 1.70
22	462A UP	JS	1	B	Hall		Metal	Radiator	Intact	4.4	11/14/2006 09:32:25	1.0	NEG	0.02 ± 0.02
23	462A UP	JS	1	B	Hall		Metal	Pipes	Intact	3.2	11/14/2006 09:32:46	1.1	NEG	0.03 ± 0.15
24	462A UP	JS	1	A	Hall	Door	Wood	Door	Intact	2.3	11/14/2006 09:33:06	1.4	POS	5.10 ± 1.00
25	462A UP	JS	1	A	Hall	Door	Wood	Casing	Intact	3.1	11/14/2006 09:33:24	1.3	NEG	0.07 ± 0.20
26	462A UP	JS	1	D	Hall	Door	Wood	Jamb	Intact	2.4	11/14/2006 09:33:43	1.6	POS	5.10 ± 1.53
27	462A UP	JS	1	D	Hall	Door	Wood	Casing	Intact	2.5	11/14/2006 09:33:55	1.3	POS	5.10 ± 1.63
28	462A UP	JS	1	D	Hall	Picture Rail	Wood		Intact	7.7	11/14/2006 09:34:20	6.6	POS	7.41 ± 1.84
29	462A UP	JS	1	D	Hall	Ceiling	Plaster		Intact	3.2	11/14/2006 09:34:45	10.0	POS	14.41 ± 5.60
30	462A UP	JS	1	C	Hall	Stairs	Wood	Stringer	Poor	2.3	11/14/2006 09:35:09	1.5	POS	5.10 ± 1.00
31	462A UP	JS	1	C	Hall	Stairs	Wood	Tread	Poor	2.4	11/14/2006 09:35:27	1.7	POS	15.26 ± 6.87
32	462A UP	JS	1	C	Hall	Stairs	Wood	Riser	Poor	2.3	11/14/2006 09:35:43	1.5	POS	5.10 ± 1.52
33	462A UP	JS	1	C	Hall	Stairs	Wood	Baluster	Poor	5.1	11/14/2006 09:36:01	1.2	NEG	0.09 ± 0.12
34	462A UP	JS	1	C	Hall	Stairs	Wood	Rail cap	Intact	3.0	11/14/2006 09:36:24	1.0	NEG	0.07 ± 0.06
35	462A UP	JS	1	C	Hall	Stairs	Wood	Newal post	Poor	3.0	11/14/2006 09:36:43	1.0	NEG	0.08 ± 0.04
36	462A UP	JS	2	A	Hall	Wall	Plaster		Intact	3.2	11/14/2006 09:40:53	10.0	POS	32.72 ± 8.17

No	Site	Insp	Flr	Side	Room	Source	Sub	Feat	Cnd	Ssec	Date/Time	DI	Result	Pbc ± Prec
37	462A UP	JS	2	B	Hall	Wall	Plaster		Intact	3.2	11/14/2006 09:41:05	4.2	POS	21.53 ± 6.78
38	462A UP	JS	2	C	Hall	Wall	Plaster		Intact	7.7	11/14/2006 09:41:19	3.1	NEG	0.01 ± 0.03
39	462A UP	JS	2	D	Hall	Wall	Plaster		Poor	3.2	11/14/2006 09:41:38	1.0	POS	23.92 ± 7.58
40	462A UP	JS	2	D	Hall	Picture Rail	Wood		Intact	5.4	11/14/2006 09:41:54	7.6	POS	5.79 ± 2.21
41	462A UP	JS	2	A	Hall		Wood	Baseboard	Poor	2.3	11/14/2006 09:42:19	1.6	POS	5.10 ± 1.50
42	462A UP	JS	2	C	Hall		Metal	Pipes	Intact	5.5	11/14/2006 09:42:41	1.0	INCOM	0.00 ± 0.08
43	462A UP	JS	2	C	Hall		Metal	Pipes	Intact	20.6	11/14/2006 09:45:27	10.0	NEG	0.12 ± 0.82
44	462A UP	JS	2	C	Hall	Door	Wood	Door	Poor	4.0	11/14/2006 09:46:15	1.4	POS	10.66 ± 2.58
45	462A UP	JS	2	C	Hall	Door	Wood	Jamb	Intact	2.3	11/14/2006 09:46:42	1.6	POS	5.10 ± 1.51
46	462A UP	JS	2	D	Hall	Door Lft	Wood	Casing	Poor	2.3	11/14/2006 09:47:11	1.3	POS	5.10 ± 1.52
47	462A UP	JS	2	D	Hall	Door Rht	Wood	Jamb	Poor	2.4	11/14/2006 09:47:47	1.2	POS	5.10 ± 1.55
48	462A UP	JS	2	B	Hall	Ceiling	Plaster		Intact	3.2	11/14/2006 09:48:26	10.0	POS	17.98 ± 6.23
49	462A UP	JS	2	C	Hall	Stairs	Wood	Stringer	Poor	2.4	11/14/2006 09:50:19	1.5	POS	5.10 ± 1.55
50	462A UP	JS	2	C	Hall	Stairs	Wood	Tread	Intact	4.3	11/14/2006 09:50:44	1.9	POS	12.55 ± 2.78
51	462A UP	JS	2	C	Hall	Stairs	Wood	Riser	Intact	2.5	11/14/2006 09:51:00	1.6	POS	5.10 ± 1.61
52	462A UP	JS	2	C	Hall	Stairs	Wood	Baluster	Intact	5.0	11/14/2006 09:51:21	1.1	NEG	0.21 ± 0.14
53	462A UP	JS	2	C	Hall	Stairs	Wood	Rail cap	Intact	5.1	11/14/2006 09:52:20	1.0	NEG	0.01 ± 0.04
54	462A UP	JS	2	A	Bath	Wall	Plaster		Intact	3.2	11/14/2006 09:53:16	1.6	POS	16.06 ± 6.11
55	462A UP	JS	2	B	Bath	Wall	Plaster		Poor	3.2	11/14/2006 09:53:29	10.0	POS	16.79 ± 5.81
56	462A UP	JS	2	C	Bath	Wall	Plaster		Intact	3.2	11/14/2006 09:53:51	3.2	POS	23.91 ± 6.40
57	462A UP	JS	2	D	Bath	Wall	Plaster		Intact	3.2	11/14/2006 09:54:04	4.6	POS	19.75 ± 6.42
58	462A UP	JS	2	D	Bath		Metal	Radiator	Poor	9.5	11/14/2006 09:54:43	1.2	NEG	0.54 ± 0.15
59	462A UP	JS	2	D	Bath		Metal	Pipes	Intact	3.2	11/14/2006 09:55:12	3.4	NEG	0.05 ± 0.28
60	462A UP	JS	2	C	Bath	Window	Wood	Apron	Intact	7.7	11/14/2006 09:55:38	10.0	POS	24.03 ± 3.36
61	462A UP	JS	2	C	Bath	Window	Wood	Stool	Poor	3.2	11/14/2006 09:56:07	8.2	POS	27.01 ± 7.43
62	462A UP	JS	2	C	Bath	Window	Wood	Stops	Intact	9.6	11/14/2006 09:56:29	5.5	NEG	0.28 ± 0.47
63	462A UP	JS	2	C	Bath	Window	Wood	Return	Poor	5.4	11/14/2006 09:57:11	10.0	POS	22.78 ± 4.06
64	462A UP	JS	2	C	Bath	Window	Wood	Casing	Poor	3.2	11/14/2006 09:57:53	10.0	POS	24.04 ± 5.99
65	462A UP	JS	2	A	Bath	Door	Wood	Door	Poor	5.4	11/14/2006 09:58:16	10.0	POS	17.92 ± 3.91
66	462A UP	JS	2	A	Bath	Door	Wood	Jamb	Poor	3.1	11/14/2006 09:58:53	5.6	POS	28.75 ± 7.06
67	462A UP	JS	2	A	Bath	Door	Wood	Casing	Poor	3.1	11/14/2006 09:59:19	1.2	NEG	0.02 ± 0.33
68	462A UP	JS	2	A	Bath	Door	Wood	Casing	Poor	3.2	11/14/2006 09:59:33	10.0	POS	21.36 ± 5.64
69	462A UP	JS	2	D	Bath		Wood	Crown mold	Poor	3.2	11/14/2006 10:00:29	10.0	POS	25.92 ± 7.14
70	462A UP	JS	2	D	Bath	Ceiling	Plaster		Intact	9.9	11/14/2006 10:00:59	1.0	POS	6.42 ± 1.63
71	462A UP	JS	2	A	B.R. 1	Wall	Plaster		Intact	12.2	11/14/2006 10:01:47	4.3	NEG	0.24 ± 0.26
72	462A UP	JS	2	B	B.R. 1	Wall	Plaster		Intact	5.4	11/14/2006 10:02:25	3.0	NEG	0.04 ± 0.23
73	462A UP	JS	2	C	B.R. 1	Wall	Plaster		Intact	7.7	11/14/2006 10:02:43	1.7	NEG	0.01 ± 0.16
74	462A UP	JS	2	D	B.R. 1	Wall	Plaster		Intact	12.2	11/14/2006 10:03:05	6.8	NEG	0.19 ± 0.31

No	Site	Insp	Flr	Side	Room	Source	Sub	Feat	Cnd	Ssec	Date/Time	DI	Result	Pbc ± Prec
75	462A UP	JS	2	D	B.R. 1	Wall	Plaster		Intact	19.1	11/14/2006 10:04:23	1.3	NEG	-0.44 ± 0.99
76	462A UP	JS	2	A	B.R. 1		Wood	Baseboard	Intact	3.1	11/14/2006 10:05:08	10.0	POS	23.42 ± 5.94
77	462A UP	JS	2	D	B.R. 1	Fireplace	Metal	Grill	Poor	3.0	11/14/2006 10:05:52	9.1	POS	10.50 ± 4.46
78	462A UP	JS	2	A	B.R. 1	Closet	Wood	Door	Intact	3.1	11/14/2006 10:06:35	9.8	POS	19.69 ± 5.23
79	462A UP	JS	2	A	B.R. 1	Closet	Wood	Jamb	Poor	2.9	11/14/2006 10:07:09	5.7	POS	29.00 ± 10.48
80	462A UP	JS	2	A	B.R. 1	Door	Wood	Casing	Poor	3.2	11/14/2006 10:07:31	10.0	POS	25.02 ± 6.18
81	462A UP	JS	2	B	B.R. 1	Door	Wood	Jamb	Poor	3.0	11/14/2006 10:07:46	9.0	POS	23.33 ± 9.27
82	462A UP	JS	2	D	B.R. 1	Picture Rail	Wood		Intact	5.2	11/14/2006 10:08:06	7.8	POS	14.96 ± 3.05
83	462A UP	JS	2	C	B.R. 1		Metal	Radiator	Intact	4.8	11/14/2006 10:08:41	1.0	NEG	0.02 ± 0.02
84	462A UP	JS	2	C	B.R. 1	Window Lft	Wood	Stool	Poor	5.4	11/14/2006 10:09:14	9.9	POS	27.24 ± 4.58
85	462A UP	JS	2	C	B.R. 1	Window Rht	Wood	Apron	Intact	5.1	11/14/2006 10:09:45	10.0	POS	21.17 ± 3.93
86	462A UP	JS	2	C	B.R. 1	Window Rht	Wood	Return	Intact	3.1	11/14/2006 10:10:20	9.3	POS	22.92 ± 5.91
87	462A UP	JS	2	C	B.R. 1	Window Rht	Wood	Stops	Intact	13.9	11/14/2006 10:10:32	10.0	POS	2.57 ± 1.03
88	462A UP	JS	2	C	B.R. 1	Window Lft	Wood	Casing	Intact	5.3	11/14/2006 10:11:06	9.0	POS	32.67 ± 5.35
89	462A UP	JS	2	A	B.R. 1	Closet	Wood	Shelf Support	Intact	3.0	11/14/2006 10:12:04	8.7	POS	23.30 ± 5.81
90	462A UP	JS	2	A	B.R. 1	Ceiling	Plaster		Intact	3.2	11/14/2006 10:12:48	10.0	POS	14.77 ± 5.13
91	462A UP	JS	2	A	Hall 1	Wall	Plaster		Intact	3.2	11/14/2006 10:13:40	5.0	POS	31.16 ± 7.86
92	462A UP	JS	2	B	Hall 1	Wall	Plaster		Intact	7.7	11/14/2006 10:13:53	1.0	NEG	0.00 ± 0.06
93	462A UP	JS	2	C	Hall 1	Wall	Plaster		Intact	3.2	11/14/2006 10:14:15	10.0	POS	34.87 ± 8.28
94	462A UP	JS	2	D	Hall 1	Wall	Plaster		Intact	5.4	11/14/2006 10:14:29	7.2	POS	27.08 ± 5.14
95	462A UP	JS	2	D	Hall 1		Wood	Baseboard	Intact	3.0	11/14/2006 10:15:08	9.7	POS	19.10 ± 5.21
96	462A UP	JS	2	A	Hall 1	Door	Wood	Jamb	Poor	3.1	11/14/2006 10:15:27	10.0	POS	25.25 ± 6.62
97	462A UP	JS	2	C	Hall 1	Door	Wood	Casing	Poor	5.3	11/14/2006 10:15:57	10.0	POS	23.31 ± 4.19
98	462A UP	JS	2	B	Hall 1	Cabinet	Wood	Door Out	Intact	3.1	11/14/2006 10:16:34	10.0	POS	34.05 ± 8.04
99	462A UP	JS	2	B	Hall 1	Cabinet	Wood	Frame	Poor	5.4	11/14/2006 10:16:49	10.0	POS	24.81 ± 4.46
100	462A UP	JS	2	B	Hall 1	Ceiling	Plaster		Intact	21.3	11/14/2006 10:17:52	1.5	NEG	0.00 ± 0.07
101	462A UP	JS	2	B	Hall 1	Ceiling	Plaster		Intact	3.0	11/14/2006 10:18:40	8.1	POS	31.44 ± 7.17
102	462A UP	JS	2	A	B.R. 2	Wall	Plaster		Intact	10.0	11/14/2006 10:19:27	7.7	NEG	0.03 ± 0.09
103	462A UP	JS	2	B	B.R. 2	Wall	Plaster		Intact	7.7	11/14/2006 10:19:51	3.2	NEG	0.11 ± 0.25
104	462A UP	JS	2	C	B.R. 2	Wall	Plaster		Intact	7.7	11/14/2006 10:20:16	5.0	NEG	0.07 ± 0.21
105	462A UP	JS	2	D	B.R. 2	Wall	Plaster		Intact	7.7	11/14/2006 10:20:43	1.0	NEG	0.00 ± 0.01
106	462A UP	JS	2	D	B.R. 2	Fireplace	Metal	Grill	Intact	2.8	11/14/2006 10:21:32	3.5	POS	19.62 ± 8.51
107	462A UP	JS	2	D	B.R. 2		Metal	Pipes	Intact	3.2	11/14/2006 10:21:48	1.1	NEG	0.06 ± 0.13
108	462A UP	JS	2	A	B.R. 2		Wood	Baseboard	Poor	3.0	11/14/2006 10:22:09	8.0	POS	21.79 ± 8.47
109	462A UP	JS	2	A	B.R. 2	Ctr	Metal	Radiator	Poor	3.0	11/14/2006 10:22:32	1.1	NEG	0.01 ± 0.24
110	462A UP	JS	2	A	B.R. 2	Window Lft	Wood	Apron	Intact	3.0	11/14/2006 10:22:50	6.7	POS	15.24 ± 6.51
111	462A UP	JS	2	A	B.R. 2	Window Lft	Wood	Casing	Intact	3.0	11/14/2006 10:23:12	7.8	POS	28.49 ± 9.79
112	462A UP	JS	2	A	B.R. 2	Window Rht	Wood	Stool	Poor	3.0	11/14/2006 10:23:26	6.1	POS	33.56 ± 7.78

No	Site	Insp	Flr	Side	Room	Source	Sub	Feat	Cnd	Ssec	Date/Time	DI	Result	Pbc ± Prec
113	462A UP	JS	2	A	B.R. 2	Window Rht	Wood	Return	Intact	3.0	11/14/2006 10:23:42	7.3	POS	22.71 ± 8.63
114	462A UP	JS	2	A	B.R. 2	Window Rht	Wood	Stops	Poor	9.6	11/14/2006 10:23:56	10.0	POS	4.64 ± 1.41
115	462A UP	JS	2	B	B.R. 2	Door	Wood	Door	Poor	3.0	11/14/2006 10:25:19	7.1	POS	24.06 ± 8.47
116	462A UP	JS	2	B	B.R. 2	Door	Wood	Jamb	Poor	2.9	11/14/2006 10:25:33	4.7	POS	19.80 ± 8.40
117	462A UP	JS	2	C	B.R. 2	Door	Wood	Casing	Poor	3.0	11/14/2006 10:25:50	7.5	POS	28.95 ± 6.60
118	462A UP	JS	2	C	B.R. 2	Closet	Wood	Shelf	Intact	2.6	11/14/2006 10:26:07	2.3	POS	17.50 ± 7.78
119	462A UP	JS	2	C	B.R. 2	Closet	Wood	Shelf Support	Intact	2.9	11/14/2006 10:26:38	4.0	POS	20.47 ± 8.44
120	462A UP	JS	2	C	B.R. 2	Closet	Plaster	Wall	Intact	4.5	11/14/2006 10:26:54	2.5	POS	33.72 ± 5.33
121	462A UP	JS	2	C	B.R. 2	Ceiling	Plaster		Intact	7.7	11/14/2006 10:27:34	10.0	POS	14.21 ± 2.70
122	462A UP	JS	2	A	B.R. 1	Closet	Plaster	Wall	Intact	2.9	11/14/2006 10:28:20	4.7	POS	39.78 ± 12.93
123	462A UP	JS	3	A	Hall	Wall	Plaster		Intact	3.2	11/14/2006 10:32:56	10.0	POS	32.54 ± 7.64
124	462A UP	JS	3	B	Hall	Wall	Plaster		Intact	3.2	11/14/2006 10:33:15	10.0	POS	32.05 ± 7.71
125	462A UP	JS	3	C	Hall	Wall	Plaster		Intact	3.2	11/14/2006 10:33:27	10.0	POS	32.23 ± 7.76
126	462A UP	JS	3	D	Hall	Wall	Plaster		Intact	3.2	11/14/2006 10:33:40	10.0	POS	32.44 ± 8.10
127	462A UP	JS	3	C	Hall		Metal	Pipes	Intact	21.1	11/14/2006 10:34:01	10.0	NEG	0.16 ± 0.65
128	462A UP	JS	3	B	Hall		Wood	Baseboard	Poor	2.4	11/14/2006 10:34:56	1.7	POS	12.93 ± 5.78
129	462A UP	JS	3	D	Hall	Stairs	Wood	Rail cap	Intact	3.0	11/14/2006 10:36:07	1.1	NEG	0.09 ± 0.17
130	462A UP	JS	3	D	Hall	Stairs	Wood	Baluster	Intact	5.1	11/14/2006 10:36:24	1.1	NEG	0.14 ± 0.13
131	462A UP	JS	3	D	Hall	OLD (lwr)	Wood	Floor	Intact	3.6	11/14/2006 10:37:05	1.5	POS	16.86 ± 3.48
132	462A UP	JS	3	C	Hall	Door	Wood	Casing	Intact	4.0	11/14/2006 10:38:13	1.4	POS	12.76 ± 2.90
133	462A UP	JS	3	D	Hall	Door	Wood	Jamb	Poor	3.9	11/14/2006 10:38:41	1.5	POS	13.96 ± 2.97
134	462A UP	JS	3	D	Hall	Door	Wood	Casing	Poor	2.3	11/14/2006 10:38:57	1.4	POS	13.93 ± 6.08
135	462A UP	JS	3	C	Hall	Wall	Plaster		Intact	3.2	11/14/2006 10:39:18	10.0	POS	31.28 ± 7.66
136	462A UP	JS	3	D	Hall	Wall	Plaster		Intact	5.4	11/14/2006 10:39:33	10.0	POS	31.92 ± 5.82
137	462A UP	JS	3	D	Hall	Picture Rail	Wood		Intact	3.2	11/14/2006 10:40:00	8.9	POS	11.80 ± 4.36
138	462A UP	JS	3	B	Hall	Ceiling	Plaster		Intact	3.2	11/14/2006 10:40:30	10.0	POS	19.16 ± 5.80
139	462A UP	JS	3	A	Dining Room	Wall	Plaster		Intact	10.0	11/14/2006 10:40:57	1.3	NEG	0.01 ± 0.09
140	462A UP	JS	3	B	Dining Room	Wall	Plaster		Intact	12.2	11/14/2006 10:41:24	10.0	NEG	-0.62 ± 1.04
141	462A UP	JS	3	C	Dining Room	Wall	Plaster		Intact	5.4	11/14/2006 10:41:53	10.0	POS	7.69 ± 2.92
142	462A UP	JS	3	D	Dining Room	Wall	Plaster		Intact	16.7	11/14/2006 10:42:10	1.1	NEG	0.00 ± 0.09
143	462A UP	JS	3	D	Dining Room		Wood	Baseboard	Intact	3.1	11/14/2006 10:42:46	8.6	POS	31.26 ± 6.80
144	462A UP	JS	3	D	Dining Room		Wood	Shelf Support	Intact	5.0	11/14/2006 10:43:05	4.8	POS	31.69 ± 5.18
145	462A UP	JS	3	D	Dining Room	Wall	Plaster		Intact	16.7	11/14/2006 10:43:25	5.4	NEG	0.05 ± 0.13
146	462A UP	JS	3	A	Dining Room	Door	Wood	Jamb	Poor	3.1	11/14/2006 10:44:13	10.0	POS	23.60 ± 6.16
147	462A UP	JS	3	B	Dining Room	Door Lft	Wood	Casing	Poor	3.0	11/14/2006 10:44:30	8.2	POS	26.78 ± 6.44
148	462A UP	JS	3	B	Dining Room	Door Rht	Wood	Casing	Poor	3.0	11/14/2006 10:44:45	8.3	POS	26.75 ± 10.22
149	462A UP	JS	3	B	Dining Room	Door Rht	Wood	Door	Poor	3.0	11/14/2006 10:44:59	10.0	POS	27.60 ± 6.88
150	462A UP	JS	3	C	Dining Room		Metal	Radiator	Intact	8.9	11/14/2006 10:45:26	1.0	NEG	0.00 ± 0.01

No	Site	Insp	Flr	Side	Room	Source	Sub	Feat	Cnd	Ssec	Date/Time	DI	Result	Pbc ± Prec
151	462A UP	JS	3	C	Dining Room	Window Lft	Wood	Return	Intact	3.1	11/14/2006 10:46:03	10.0	POS	29.59 ± 6.82
152	462A UP	JS	3	C	Dining Room	Window Lft	Wood	Casing	Intact	7.5	11/14/2006 10:46:17	10.0	POS	26.52 ± 3.64
153	462A UP	JS	3	C	Dining Room	Window Rht	Wood	Apron	Intact	3.1	11/14/2006 10:46:55	10.0	POS	28.21 ± 6.73
154	462A UP	JS	3	C	Dining Room	Window Rht	Wood	Stops	Intact	5.3	11/14/2006 10:47:25	3.3	NEG	0.06 ± 0.33
155	462A UP	JS	3	C	Dining Room	Window Lft	Wood	Stops	Intact	9.6	11/14/2006 10:47:42	5.1	NEG	0.36 ± 0.42
156	462A UP	JS	3	C	Dining Room	Ceiling	Plaster		Intact	10.0	11/14/2006 10:48:47	2.6	POS	3.50 ± 1.38
157	462A UP	JS	3	A	Bath	Wall	Plaster		Intact	3.2	11/14/2006 10:50:46	1.0	POS	17.91 ± 5.85
158	462A UP	JS	3	B	Bath	Wall	Plaster		Intact	3.2	11/14/2006 10:51:01	10.0	POS	17.63 ± 6.21
159	462A UP	JS	3	C	Bath	Wall	Plaster		Intact	3.2	11/14/2006 10:51:13	3.8	POS	20.93 ± 5.75
160	462A UP	JS	3	D	Bath	Wall	Plaster		Intact	3.2	11/14/2006 10:51:25	4.8	POS	19.64 ± 5.75
161	462A UP	JS	3	D	Bath		Wood	Baseboard	Intact	3.1	11/14/2006 10:51:39	10.0	POS	26.60 ± 6.09
162	462A UP	JS	3	A	Bath	Door	Wood	Door	Poor	5.2	11/14/2006 10:52:03	10.0	POS	24.22 ± 4.28
163	462A UP	JS	3	A	Bath	Door	Wood	Casing	Poor	3.1	11/14/2006 10:52:28	10.0	POS	30.52 ± 6.40
164	462A UP	JS	3	C	Bath	Door	Wood	Jamb	Intact	3.1	11/14/2006 10:52:50	10.0	POS	26.06 ± 6.01
165	462A UP	JS	3	C	Bath	Window	Wood	Apron	Intact	3.2	11/14/2006 10:53:04	10.0	POS	23.08 ± 6.07
166	462A UP	JS	3	C	Bath	Window	Wood	Stool	Intact	3.1	11/14/2006 10:53:16	10.0	POS	18.33 ± 5.29
167	462A UP	JS	3	C	Bath	Window	Wood	Return	Intact	3.1	11/14/2006 10:53:29	10.0	POS	24.63 ± 6.08
168	462A UP	JS	3	C	Bath	Window	Wood	Stops	Intact	3.1	11/14/2006 10:53:42	1.0	NEG	0.05 ± 0.12
169	462A UP	JS	3	C	Bath	Window	Wood	Casing	Poor	3.1	11/14/2006 10:53:55	10.0	POS	23.23 ± 5.74
170	462A UP	JS	3	C	Bath		Metal	Radiator	Intact	5.0	11/14/2006 10:54:13	1.0	NEG	0.00 ± 0.03
171	462A UP	JS	3	D	Bath	Ceiling	Plaster		Intact	5.4	11/14/2006 10:54:48	1.0	POS	7.21 ± 2.46
172	462A UP	JS	3	A	Kitchen	Wall	Plaster		Poor	5.4	11/14/2006 10:55:37	1.0	NEG	0.00 ± 0.01
173	462A UP	JS	3	B	Kitchen	Wall	Plaster		Intact	5.4	11/14/2006 10:55:57	1.0	NEG	0.00 ± 0.03
174	462A UP	JS	3	C	Kitchen	Wall	Plaster		Poor	3.2	11/14/2006 10:56:15	10.0	POS	22.40 ± 6.75
175	462A UP	JS	3	D	Kitchen	Wall	Plaster		Intact	16.7	11/14/2006 10:56:31	1.0	NEG	0.00 ± 0.04
176	462A UP	JS	3	B	Kitchen	Cabinet	Wood	Door Out	Poor	5.1	11/14/2006 10:57:40	4.2	POS	7.14 ± 2.14
177	462A UP	JS	3	B	Kitchen	Cabinet	Wood	Frame	Poor	3.0	11/14/2006 10:58:12	5.0	POS	9.07 ± 3.49
178	462A UP	JS	3	B	Kitchen		Wood	Crown mold	Intact	3.1	11/14/2006 10:58:37	10.0	POS	15.80 ± 4.83
179	462A UP	JS	3	B	Kitchen		Metal	Pipes	Intact	3.1	11/14/2006 10:58:53	1.0	NEG	0.01 ± 0.13
180	462A UP	JS	3	A	Kitchen	Door	Wood	Jamb	Poor	3.0	11/14/2006 10:59:13	10.0	POS	13.39 ± 4.59
181	462A UP	JS	3	C	Kitchen	Ceiling	Wood	Casing	Poor	5.1	11/14/2006 10:59:31	6.3	POS	13.52 ± 3.02
182	462A UP	JS	3	B	Kitchen	Ceiling	Wood	Chute	Intact	5.3	11/14/2006 11:00:16	6.9	POS	6.85 ± 2.01
183	462A UP	JS	3	B	Kitchen	Door	Wood	Casing	Intact	11.7	11/14/2006 11:00:33	9.9	POS	3.29 ± 1.16
184	462A UP	JS	3	B	Kitchen	Ceiling	Plaster		Intact	5.4	11/14/2006 11:01:31	10.0	POS	10.43 ± 3.22
185	462A UP	JS	3	A	Living Room	Wall	Plaster		Intact	11.5	11/14/2006 11:02:15	2.2	POS	1.62 ± 0.36
186	462A UP	JS	3	B	Living Room	Wall	Plaster		Intact	9.5	11/14/2006 11:02:44	2.6	POS	1.79 ± 0.49
187	462A UP	JS	3	C	Living Room	Wall	Plaster		Intact	7.3	11/14/2006 11:03:09	3.6	POS	3.27 ± 1.09
188	462A UP	JS	3	D	Living Room	Wall	Plaster		Intact	9.4	11/14/2006 11:03:34	3.0	POS	2.13 ± 0.60

No	Site	Insp	Flr	Side	Room	Source	Sub	Feat	Cnd	Ssec	Date/Time	DI	Result	Pbc ± Prec
189	462A UP	JS	3	D	Living Room	Fireplace	Metal	inside Wall	Intact	3.0	11/14/2006 11:04:06	2.0	NEG	0.25 ± 0.34
190	462A UP	JS	3	D	Living Room	Fireplace	Metal	inside Wall	Intact	3.2	11/14/2006 11:04:17	1.9	NEG	0.20 ± 0.29
191	462A UP	JS	3	D	Living Room		Wood	Baseboard	Poor	2.6	11/14/2006 11:04:38	3.0	POS	31.21 ± 11.39
192	462A UP	JS	3	C	Living Room	Closet Rht	Wood	Door	Poor	2.6	11/14/2006 11:05:19	2.7	POS	34.84 ± 11.39
193	462A UP	JS	3	C	Living Room	Door Rht	Wood	Jamb	Poor	2.6	11/14/2006 11:05:35	2.5	POS	25.14 ± 9.79
194	462A UP	JS	3	C	Living Room	Door Lft	Wood	Casing	Intact	2.6	11/14/2006 11:05:55	2.4	POS	15.74 ± 6.80
195	462A UP	JS	3	C	Living Room	Door Lft	Wood	Door	Poor	2.6	11/14/2006 11:06:09	2.3	POS	29.11 ± 9.79
196	462A UP	JS	3	C	Living Room	Picture Rail	Wood		Intact	7.5	11/14/2006 11:06:24	3.8	POS	4.73 ± 1.59
197	462A UP	JS	3	A	Living Room		Metal	Radiator	Intact	4.9	11/14/2006 11:06:51	1.0	NEG	0.03 ± 0.06
198	462A UP	JS	3	A	Living Room	Window	Wood	Casing	Poor	2.5	11/14/2006 11:07:17	2.4	POS	26.55 ± 9.36
199	462A UP	JS	3	A	Living Room	Window	Wood	Stool	Poor	2.6	11/14/2006 11:07:30	2.6	POS	32.00 ± 10.14
200	462A UP	JS	3	A	Living Room	Window Ctr	Wood	Apron	Poor	2.6	11/14/2006 11:07:48	2.8	POS	31.21 ± 9.56
201	462A UP	JS	3	A	Living Room	Window Lft	Wood	Casing	Poor	2.6	11/14/2006 11:08:04	2.4	POS	30.00 ± 10.47
202	462A UP	JS	3	A	Living Room	Window Lft	Wood	Return	Intact	2.5	11/14/2006 11:08:17	2.6	POS	32.95 ± 10.92
203	462A UP	JS	3	A	Living Room	Window Lft	Wood	Stops	Intact	13.9	11/14/2006 11:08:34	3.9	NEG	0.52 ± 0.29
204	462A UP	JS	3	C	Living Room	Ceiling	Plaster		Intact	5.5	11/14/2006 11:09:24	1.0	POS	7.50 ± 2.31
205	462A UP	JS			Calibrate	XRF		Lead Standard 0.3	OK	7.1	11/14/2006 11:10:21	1.0	NEG	0.27 ± 0.11
206	462A UP	JS			Calibrate	XRF		Lead Standard 0.0	OK	7.2	11/14/2006 11:10:38	1.0	NEG	0.00 ± 0.01
207	462A UP	JS			Calibrate	XRF		Lead Standard 1.0	OK	22.9	11/14/2006 11:10:54	1.0	POS	0.98 ± 0.11